

Bison Innovative Products

701 Osage Street, Unit 120
Denver, CO 80204
info@bisonip.com
www.bisonip.com

Phone 303-892-0400
Toll Free 800-333-4234
Fax 303-825-5988

September 2020



PAVER TRAY Specification

Ideal for use with Bison Pedestals, the Bison Paver Tray offers a simple and lightweight paver backing to enhance the impact resistance and provide additional strength to paver surface materials for outdoor areas. The Bison Paver Tray can be adhered to the desired surface pavers on site before or during installation. Recommended for use with Bison Pedestals ranging from 1/8" to 36" in height, the Bison Paver Tray attaches to Bison Pedestals 1/2" in height or taller using the Bison FS-12 Fastening Spline.

Bison Paver Tray System Specification

SECTION 073214 Ceramic and Porcelain Roof Tiles

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Bison Paver Tray for use with ceramic or porcelain roof pavers on pedestal systems.

1.2 RELATED SECTIONS

**** NOTE TO SPECIFIER **** Delete any sections below not relevant to this project; add others as required.

- A. Section 042000 – Unit Masonry and Accessories
- B. Section 044000 – Stone Assemblies
- C. Section 044100 – Dry-Placed Stone
- D. Section 075000 – Membrane Roofing
- E. Section 077246 – Roof Walkways
- F. Section 077600 – Roof Pavers
- G. Section 077616 – Roof Decking Pavers
- H. Section 093000 – Tiling
- I. Section 096900 – Access Flooring
- J. Section 321400 – Unit Paving

1.3 REFERENCES

**** NOTE TO SPECIFIER **** Delete references from the list below that are not actually required by the text of the edited section.

Bison Paver Tray and 2CM Paver System Testing:

- A. ASTM C297 – Standard Test Method for Flatwise Tensile Strength of Sandwich Constructions
- B. ASTM D905 – Standard Test Method for Strength Properties of Adhesive Bonds in Shear by Compressive Loading
- C. ASTM D1183 – Standard Practice for Resistance of Adhesives to Cyclic Laboratory Aging Conditions
- D. ASTM E108 – Standard Test Methods for Fire Tests of Roof Coverings
- E. ASTM E136 – Standard Test Method for Assessing Combustibility of Materials Using a Vertical Tube Furnace at 750°C
- F. ASTM E661 – Standard Test Method for Performance of Wood and Wood-Based Floor and Roof Sheathing Under Concentrated Static and Impact Loads
- G. ASTM E2322 – Standard Test Method for Conducting Transverse and Concentrated Load Tests on Panels used in Floor and Roof Construction
- H. CISCA Association Recommended Test Procedures for Access Floors - Section 7 Uniform Load Test
- I. LARR 26041 – Versadjust FR Pedestal System up to 36", Bison Paver Tray and 2CM Paver
- J. LARR T872 – ScrewJack FR Pedestal System up to 24", Bison Paver Tray and 2CM Paver
- K. UL TGFU R38623 – UL Exterior Fire Classifications

1.4 SUBMITTALS

- A. Submit under provisions of Section 013300.
- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage/Handling requirements and recommendations.
 - 3. Installation methods.
- C. Shop Drawings: Submit shop drawings detailing the installation methods. Coordinate placement with locations noted on the Contract Drawings.
- D. Fire Resistance Ratings: As required for exterior pedestal supported deck systems by the presiding jurisdiction.
- E. Wind Uplift Ratings: As required for exterior air permeable pedestal supported deck systems by the presiding jurisdiction.

1.5 QUALITY ASSURANCE

- A. Manufacturer Qualifications: All primary products specified in this section will be supplied by a single Manufacturer with five (5) years of experience minimum.
 - B. Installer Qualifications: Bison recommends the Installer have a minimum of two (2) years proven construction experience, be capable of estimating and building from blueprint plans and details, determining elevations, and properly handling materials. All work must comply with the Bison installation procedures for pedestals specified herein.
 - C. Special Considerations: The Contractor assumes the responsibility for and must take into consideration the structural capability and adequacy of the structure to carry the dead and live load weight(s) involved, and when appropriate, make sure that the density of any insulation is satisfactory to resist crushing and damaging the waterproofing membrane.
 - D. The Bison Pedestal System is not intended to be part of a ballasted roofing system and does not shield the underlying roofing system from wind or other loads. The underlying roofing system must be capable of resisting the full design wind or other loads appropriate for a specific project.
- ** NOTE TO SPECIFIER **** Include a mock-up if the project size and/or quality warrant taking such a precaution. The following is one example of how a mock-up on a large project might be specified. When deciding on the extent of the mock-up, consider all the major different types of work on the project.
- E. Mock-Up: Provide a mock-up for evaluation of surface preparation techniques and application workmanship.
 - 1. Finish areas designated by Architect.

2. Do not proceed with remaining work until workmanship is approved by Architect (if applicable).
3. Refinish mock-up area as required to produce acceptable work.

1.6 DELIVERY, STORAGE, AND HANDLING

- A. Deliver and store Bison Paver Trays and system components with labels intact and legible.
- B. Immediately upon receipt inspect all delivered materials to ensure they are undamaged and in good condition. Claims for damages must be made to the Driver/Carrier *prior* to accepting delivery. Note any visual damage to containers or packaging material on the bill of lading *before* the Driver leaves. Any damage should be noted on the bill of lading, photographed, and then reported to Bison immediately.
- C. Store Bison Paver Trays out of direct sunlight in a dry area and/or cover with tarp.
- D. Store and dispose of solvent-based materials such as construction adhesives or paint thinners in accordance with requirements of local authorities having jurisdiction.
- E. In each Order include an additional 5-10% in spare Paver Tray material to have on hand for damage replacement; depending on the size of the job and as directed by the Architect.

1.7 PROJECT CONDITIONS

- A. Bison Paver Trays listed in this section are for use with pedestrian traffic only. Bison Paver Trays are not designed for supporting decks that carry vehicular traffic or equipment, including but not limited to motorized snow removal equipment, window washing, scaffolding structures, ATV's, forklifts, or any motorized vehicles.
- B. The recommended minimum installation temperature is 40°F (5°C) and rising. **IMPORTANT:** Ceramic and porcelain pavers can both become brittle in extremely cold conditions. Use additional caution when working with pavers in temperatures colder than 40°F (5°C). If breakage occurs, replace the paver and Paver Tray immediately.
- C. It is recommended that the Bison Paver Trays sit above the waterproofing, integral flashing, and/or counter flashing. In situations where the perimeter of the deck contacts the flashing material, protective wall covering should be specified if deemed necessary.
- D. **IMPORTANT:** It is the responsibility of the installer to make sure the installation of the Bison Paver Tray System meets all local and national codes, including but not limited to the National Electrical Code, regarding installations around swimming pools or other water features, which may require grounding and/or bonding. Failure to do this may void warranties or cause the risk of shock or serious injury for which Bison is not responsible.
- E. Bison recommends designating zones in each project that provide for heavier features with additional pedestal supports and/or different deck materials under the finished feature. Refer to pedestal specifications and details for additional information on weight capacities and supports. Any feature that creates vibration, cell phone towers, heavy planters, and other similar features require their own separate support designed by an Architect or Engineer of Record. Any deck features that provide a concentrated load must have extra supports in addition to the primary pedestal grid that supports the walk deck. Features supported by legs or feet are not advised and are considered unacceptable because of the consequences of point loading. Bison does not recommend point loading pavers as likelihood for damage is greatly increased. Permanent features and items greater than 250 lbs (113 kg) should be installed directly on pedestals in lieu of installing over surface pavers. Features weighing less than 250 lbs. (113 kg) may be installed on top of pavers as long as weight is evenly dispersed. Bison recommends designating zones in each project that provide for heavier features with additional pedestal supports and/or reinforced deck materials under the finished pavers.

1.8 WARRANTY

- A. At project closeout and upon request, Bison can provide to the Owner or Owner's Representative an executed copy of the Manufacturer's standard document outlining the terms, conditions, and limitations of their limited warranty against manufacturing defects for a period of five (5) years. Bison must approve all warranty related repairs, and unauthorized repairs void this limited warranty.
- B. The Contractor warrants that his work will remain free from defects of labor and materials used in conjunction with his work in accordance with the General Conditions for this project or a minimum of five (5) years.
- C. It is the responsibility of the Contractor installing the product listed in this section to coordinate warranty requirements with any related sections or adjacent work. Notify the Architect immediately of any potential lapses or limitations in warranty coverage.
- D. Bison Paver Trays are covered by a limited five (5) year warranty. Bison Paver Trays are warranted to the original Owner to be free of defects in material and workmanship for the period of five (5) years from the date of purchase. Damage to the Bison Paver Tray resulting from impact or broken surface material is not covered by the warranty. Bison is not responsible or liable for the cost of any Bison Paver Tray that breaks unless such breakage is caused by a defect in material or workmanship. This warranty applies to conditions of normal use, as defined herein, and does not apply to damage resulting from abuse, excess weight, impact, or acts of nature. Bison's sole and exclusive liability under this warranty is limited to the replacement cost of any defective Bison Paver Tray. This warranty does not cover shipping damage. Shipping damage must be reported directly to Bison immediately upon receipt of products. Please save all product packaging for a short period of time in case return shipping is required. Bison makes no other warranties, either express or implied, with respect to the use of the Bison Paver Tray, including warranties of merchantability or fitness for a particular purpose.

1.9 MANUFACTURERS

****NOTE TO SPECIFIER**** Retain one of the following paragraphs 1.9 A-C; to coordinate with requirements of Division 1 section on product options and substitutions.

- A. Acceptable Bison Paver Tray Manufacturer: Bison Innovative Products; 701 Osage Street, Unit 120, Denver, CO 80204.
Toll Free 800-333-4234. Phone 303-892-0400. Fax 303-825-5988. Email: info@bisonip.com. Web: www.bisonip.com.
- B. Substitutions: Not Permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 012500.

PART 2 PRODUCTS

The Bison Paver Tray will not prevent any surface material from cracking, chipping, or breaking. In the event the surface material cracks, chips, or breaks, the Bison Paver Tray is designed to help prevent an individual from falling through the paver surface to the subsurface below. The Bison Paver Tray is intended to support the surface material after absorbing impact for a limited time. To avoid further damage or injury, the customer **MUST REPLACE** any cracked, chipped, or broken surface materials and the accompanying Bison Paver Trays as soon as possible. The Bison Paver Tray is not intended to be a reusable product and must be replaced with the surface paver. When using Bison Paver Trays with customer supplied surface materials, including but not limited to concrete, stone, porcelain, and/or ceramic pavers not sold by Bison, the customer **MUST** independently verify surface material product strength, span, weight bearing capacity, material compatibility, and suitability for the intended use. **IMPORTANT:** Wind Uplift Systems must be installed precisely according to separate Wind Uplift Engineering documents not included herein.

2.1 BISON PAVER TRAYS

A. Model PT-TRAY-2424-4

1. Dimensions: 23.43”L x 23.43”W x 0.35”H (595 x 595 x 9 mm)
2. Paver Size: Fits 595-603 x 595-603 mm pavers
3. Weight: 6 lbs (2.72 kg)
4. Component Materials:
 - a. G90 Galvanized 20 ga Sheet Steel – LEED Information--contains approximately: 55.2% Scrap Steel; 41.3% Alloys and other Iron Units; 37.2% Post-Consumer Recycled Content; 18.0% Pre-Consumer Recycled Content
 - b. Polyurethane Adhesive Sealant – Color: Grey; VOC Content: 29.0 g/l; Service Temperature: -40°F-194°F; Specific Gravity: 1.17 g/cm³; Tack-Free Time @73°F and 50% Relative Humidity: 50-90 minutes; Rate of Cure @ 73°F and 50% Relative Humidity: 3/16 in per 24hrs; Shore A Hardness ASTM C661: 45; Tensile Strength ASTM D412: 450 psi; 100% Modulus ASTM D412: 150 psi; Weight: 0.12 lbs

B. Model PT-TRAY-4812-3 (Special Order ONLY)

1. Dimensions: 47.01”L x 11.61”W x 0.45”H (1194 x 295 x 12 mm)
2. Paver Size: Fits 1194-1201 x 295-302 mm pavers
3. Weight: 9.59 lbs (4.35 kg)
4. Component Materials:
 - a. G90 Galvanized 20 ga. Sheet Steel – LEED Information--contains approximately: 55.2% Scrap Steel; 41.3% Alloys and other Iron Units; 37.2% Post-Consumer Recycled Content; 18.0% Pre-Consumer Recycled Content
 - b. Peel and Stick Butyl Adhesive Pad – Color: Black; Odor: No Objectable Odors; Service Temperature: -20F-200F; %Solids: >99%; Specific Gravity: 1.60 +/- 0.05 g/cm³; Tensile Yield: Cohesive Failure 17 psi; Weight: 1.55 lbs +/- 0.10 lbs

C. Model PT-TRAY-4824-3 (Special Order ONLY)

1. Dimensions: 47.01”L x 23.43”W x 0.45”H (1194 x 595 x 12 mm)
2. Paver Size: Fits 1194-1201 x 595-602 mm pavers
3. Weight: 19.07 lbs (8.65 kg)
4. Component Materials:
 - a. G90 Galvanized 20 ga. Sheet Steel – LEED Information--contains approximately: 55.2% Scrap Steel; 41.3% Alloys and other Iron Units; 37.2% Post-Consumer Recycled Content; 18.0% Pre-Consumer Recycled Content
 - b. Peel and Stick Butyl Adhesive Pad – Color: Black; Odor: No Objectable Odors; Service Temperature: -20F-200F; %Solids: >99%; Specific Gravity: 1.60 +/- 0.05 g/cm³; Tensile Yield: Cohesive Failure 17 psi; Weight: 1.55 lbs +/- 0.10 lbs

2.2 BISON PAVER TRAY FASTENER

A. Model: FS-12 Spline – Secures Bison Paver Tray Assemblies to Bison Pedestals:

1. Strongly recommended for use with Bison Pedestals and Paver Tray Assemblies.
2. Components: Spline, long screw, and short screw – long screw for use with Bison Adjustable Pedestals; short screw for use with Bison HD50 and HD75 Fixed Height Pedestals.
3. Weight: 1.41 oz (40 g)
4. Component Material: Mineral Filled High Density Copolymer Polypropylene (Bison #B-PP-2025)

PART 3 EXECUTION

3.1 EXAMINATION

**** NOTE TO SPECIFIER **** *Revise the next paragraph to accommodate method of installation on the project.*

The Bison Paver Tray System is not designed for supporting decks that carry vehicular traffic or equipment including but not limited to snow removal equipment, window washing or other scaffolding, ATV's, forklifts, or any motorized vehicles. Decks must be restrained by perimeter blocking or walls on all sides. Lateral movement greater than 3/16” inch (4.5 mm) is unacceptable and will be rejected.

A. Consult the Manufacturer and/or an Engineer regarding the following:

1. When design requires spacing between pavers other than the standard spacing required by the manufacturer.
2. When load capacity exceeds the maximums listed.
3. When using pavers over pedestals on grade (soil).
4. When using features with point loads greater than 100 lbs (45.34kg).
5. When installing a deck using pedestals over 36” (914.4 mm) in height.
6. When installing over a joist system.
7. When installing the Bison Paver Tray with surface materials other than 2cm pavers.

B. Prior to Bison Paver Tray and paver assembly and/or installation verify the following:

1. All elevations and deck dimensions are consistent with information submitted to Bison for quoting and/or take-off.
2. Special features and anticipated live/dead loads on the Paver Tray Assemblies are compatible with the deck system.
3. Substrates have been properly prepared, and the project is set to proceed. If substrate preparation is the responsibility of another Installer, notify Architect of unsatisfactory preparation before proceeding. Verify all elevations, potential obstructions, and deck dimensions before commencing work.

3.2 PREPARATION

A. The substrate surface that will receive the Bison Pedestals and Paver Trays must be:

1. Well compacted if on-grade.
2. Structurally capable of carrying the dead and live loads anticipated if over occupied space.
3. Clean and free of debris that could impair the performance of the Bison Pedestals or Cubes.

B. Prior to assembling the Bison Paver Tray and 2cm paver, Bison recommends that the installer verify the as built conditions of the job and inventory materials.

- C. Be aware that stone, ceramic, or porcelain tiles/pavers tend to be brittle and fragile. Take time to determine how you will handle and install the pavers to ensure they are not damaged during the installation process. Wear puncture resistant work gloves when handling to protect hands from pinching, cuts, or other possible hand injuries.
- D. The Bison Paver Tray can be adhered to the desired surface pavers on site PRIOR TO or DURING INSTALLATION. Determine a method for assembling the paver to the Bison Paver Tray which:

1. Prevents damage to the paver surface.
 2. Ensures the Bison Paver Tray is adhered to the paver properly (i.e. square/flush).
- E. Paver Tray Pre-Installation Assembly – Adhering a 2cm Paver to the Paver Tray PRIOR TO INSTALLATION:
1. During assembly, limit exposure to moisture, direct sunlight, and temperatures outside of 40°F to 100°F (5°C to 37°C). CAUTION: Use gloves when handling trays.
 2. Squarely place a paver finish face down over four (4x) pedestals. Pull pavers from different pallets and/or boxes in order to achieve an even color distribution.
 3. Run a 1/8" DIA. bead of provided 3M adhesive, offset 1/4" from the top outer edge of the tray, and a 1/8" DIA. bead alongside each line of holes. IMPORTANT: For proper adhesion and performance, adhesive must be applied exactly as described. To prevent moisture from entering between paver and tray, a continuous perimeter bead of adhesive must be installed along the edge of the tray.
 4. Place the adhesive side of the tray squarely onto the paver, carefully aligning by hand to make sure that the tray does not extend beyond any edge of the paver.
 5. Repeating the first four steps, gently lay each new paver on top of the previous tray, rotating placement as assembly continues. Stacking no more than ten (10x) paver tray assemblies high, let sit for 2 to 4 hours, or until the adhesive has cured, before handling.
- F. Once the Paver Tray Assemblies are stacked, establish the deck layout and arrange pedestals for the initial layout (e.g. T-Method). It is easier to set the preliminary height of the pedestals before installing the pavers. Establish accurate lines, levels, pattern, and perimeter containment. Use a laser level to determine even and level paver height across the desired deck surface.

3.3 INSTALLATION

- A. Reference the most up to date version of Bison Paver Tray Assembly & Installation Guide and CAD Details for recommended installation procedures. NOTE: Additional Bison Installation Details are available online at www.bisonip.com. If a scenario is encountered during installation which is not covered in the Guide or Details, please contact Bison.
- B. Paver Tray & 2cm Installation Assembly – Adhering a 2cm Paver to the Paver Tray DURING INSTALLATION:
1. During installation assembly, limit exposure to moisture, direct sunlight, and temperatures outside of 40°F to 100°F (5°C to 37°C). CAUTION: Use gloves when handling trays.
 2. Place a paver tray on four (4x) pedestals and remove tabs as needed for perimeter placement and also along the path of the FS-12 fasteners.
 3. Run a 1/8" DIA. bead of provided 3M adhesive, offset 1/4" from the top outer edge of the tray, and a 1/8" DIA. bead alongside each line of holes. IMPORTANT: For proper adhesion and performance, adhesive must be applied exactly as described. To prevent moisture from entering between paver and tray, a continuous perimeter bead of adhesive must be installed along the edge of the tray.
 4. Place the 2cm paver squarely onto the tray, carefully aligning by hand to make sure that the tray does not extend beyond any edge of the paver. Pull pavers from different pallets and/or boxes in order to achieve an even color distribution.
 5. Repeat the first four steps, moving out from the perimeter wall.
 6. Following the Bison T-Method, as installation progresses out from the perimeter wall, work can also begin along the length of the wall. Place FS-12 fasteners in the channel created between the bottom of the paver and the tray as installation continues outward. These will help to maintain spacing and will be screwed into the pedestals to lock the system together. Once all pavers are installed and adhesive has had time to cure, carefully remove the FS-12 posts with pliers to avoid chipping. DO NOT attempt to hammer the spline posts.
- C. General Safety Precautions: Wear safety glasses with side shields (or a safety visor which protects one's face and eyes) when cutting this product, or during any process which may generate excessive dusts and burrs. Respirators must be worn if the ambient concentration of airborne contaminants exceeds prescribed exposure limits (see OSHA Guidelines). Dust masks may be worn to avoid the inhalation of nuisance dust, but dust masks are not adequate protection in environments above the occupational exposure limit. Any cutting or grinding process which could generate airborne particulates should be done outdoors or in a well-ventilated area. Refer to product SDS for more information. If installing Bison Paver Trays near Bison Wood Tiles take EXTREME CAUTION to cover the Wood Tiles and prevent grinding dusts from settling on them, as the galvanized dust reacting with the acetic acid in the wood can lead to black spotting on the Wood Tiles as the iron in the dust begins to oxidize into a black-colored rust.
- D. The recommended minimum installation temperature is 40°F (5°C) and rising. IMPORTANT: Pavers can become brittle in extremely cold conditions. Use additional caution when handling, working with, or working on top of pavers in temperatures colder than 40°F (5°C).
- E. The Bison Paver Tray System can be installed over Bison Pedestals ranging from 1/8" (3.2 mm) to 36" (914.4 mm) in height. The Bison Paver Tray attaches to Bison Pedestals 1/2" (12.7 mm) in height or taller using the Bison FS-12 Fastening Spline. Additional bracing is required for pedestal heights between 24" (609.6 mm) and 36" (914.4 mm). Please refer to the Bison Pedestal Specifications and Installation Details for more information.
- F. Cutting:
1. Bison recommends cutting Bison Paver Trays and 2cm pavers separately.
 2. When cutting, ensure you have all the proper safety equipment: hearing, respiratory, eye, and hand protection are highly recommended.
 3. Using an angle grinder with a dry cutting 4" to 4-1/2" diameter tuck-point or mesh blade to score 1/8" depth along the desired cut line for both straight and curved cuts. Following the score line, proceed to cut entire depth of paver. Score lines are meant to prevent and control fracturing of finish paver. At full cut depth, if curve cut radius creates too much stress on the blade, consider cutting relief cuts incrementally up to score line. To mitigate possible chipping consider using a mesh blade.
 4. Once paver has been cut to desired profile, place it on the tray, aligning paver sides with sides of tray. Match your paver cut line by tracing your cut line. Use an angle grinder with a 4" to 4-1/2" diameter non-stainless steel cutting wheel to cut the tray along the trace line. A jig saw or band saw may also be practical for cutting trays. Use a metal file or angle grinder to remove any sharp burrs. DO NOT run your fingers along the cut line or any visible burrs. For optimal quality in cutting the tray consider using a sheet metal shear.
 5. Once both paver and tray have been cut to desired profile, follow Bison's recommended assembly instructions, making sure to remove any dirt or debris from surfaces before applying 3M adhesive.
 6. Use a cleaner such as Goof Off to remove any adhesive residue from the saw blade. Spray a small amount of cleaner on the undesirable adhesive location and rub until clean. Wash with a clean rag and mild soap to remove any slippery residue.
 7. If using an abrasive cutting wheel for the tray, paint the cut edges with a primer of cold galvanizing spray to readminister galvanizing layer removed by cutting (exposure to heat, grinding, and/or water) to prevent rusting damage.
- G. Fastening to Bison Pedestals:
1. Combine the Bison Paver Tray with the Bison FS-12 Spline and Pedestals for an unparalleled combination of collapse resistance, concealed stability, and future cavity accessibility.
 2. Bison strongly recommends the use of Bison Pedestals and FS-12 Splines when installing Bison Paver Trays in conjunction with surface pavers. The Bison FS-12 Spline installs quickly, securely, and allows for removal later if desired/required. The FS-12 Splines, available exclusively from Bison, secure the Bison Paver Trays to Bison Pedestals while remaining out of sight without damaging the paver surfaces. A long screw is provided for use with Bison Adjustable Pedestals, and a short screw is provided for use with Bison HD50 and HD75 Fixed Height Pedestals.

3. To install the FS-12 Spline, use the spline posts to slide FS-12 Splines into the channel between two adjacent Paver Tray Assemblies.
4. Use a T-10 star bit and the included long screw to secure the FS-12 Spline to Bison Adjustable Pedestals, or use a #1 square bit and the included short screw to secure the FS-12 Spline to Bison HD50 or HD75 Fixed Height Pedestals. Bison recommends the use of a GRK extended bit from your local hardware store for easier installation.
5. Drive the screw through the center of the spline screw slot and into the center of the pedestal top. Tighten until the screw head base is flush with the top of the spline rib. Remove spline posts with pliers, taking care not to damage the pavers. A small screwdriver can be used to manipulate the spline if the posts have been prematurely removed.

3.4 FIELD QUALITY CONTROL

A. During Installation:

1. Inspect construction progress regularly to ensure that grid lines and spacing are being maintained in a straight and consistent pattern, lateral motion is restricted, and the Paver Tray Assemblies and Pedestals are level and not rocking; shim as required. Particular attention should be paid to pedestrian entrances or access points to eliminate potential trip hazards.
2. Inspect to ensure that all perimeter sides of the deck system are securely contained to restrain all sides of the deck. Surface materials must fit tightly against all pedestal spacing tabs, and the gap or space at all perimeter edges must not exceed one tab width or 3/16" (4.5 mm).
3. While pavers are durable, they can be damaged by mishandling or careless treatment. Please note that if tools or equipment are carelessly dropped on the paver surface, chips, scratches, surface damage, cracking, and breakage can occur, especially in cold temperatures. Replace cracked, chipped, or damaged Paver Tray Assemblies immediately.

B. Immediately Following Installation: The Owner, or the Owner's Agent, shall carefully inspect the deck system to be positive that:

1. The new deck system is adequately blocked on all sides to contain and prevent lateral movement of the surface decking and related components.
2. There is no more than one tab width spacing between any pavers or from perimeter containment [not to exceed 3/16" (4.5 mm)].
3. There is no rocking of Paver Tray Assemblies as foot traffic is applied to the surface decking.
4. All required spacer tabs and fastening kits are installed and secure.
5. The installed pavers are protected from damage which may result from continued site construction. Protect installed pavers by using sheet(s) of plywood to cover work areas and protect the pavers from chipping and breakage. Use caution if using protective plastic sheeting as it may become extremely slippery as construction dust settles.

C. After Installation: The Installer and/or Architect has the responsibility of informing the Owner about performing routine maintenance on the deck. This includes:

1. Checking for rocking pavers and properly applying shims as the substrate can settle and require pedestal adjustment.
2. Periodically checking for broken, damaged, or missing tab sets and replacing them to limit deck movement.
3. Maintaining intact and structurally sound perimeter containment.
4. IMMEDIATELY replacing cracked, chipped, broken, or damaged Bison Paver Tray Assemblies or Pedestals. If a paver requires replacement, then the Bison Paver Tray which accompanied it *also requires replacement* even if the damage to the paver appears to be only on the "surface".
5. Retaining extra pavers and Bison Paver Trays and pavers in a convenient location for future replacements.

3.5 CARE & MAINTENANCE

Test any cleaners in an inconspicuous area first before applying them to the installed deck to determine whether the product you are about to apply serves its intended purpose. In addition, always check with the manufacturer of your roof membrane to ensure that any cleaning solution or product will not compromise or damage the waterproofing membrane. Remember to use safety glasses, respirators, and gloves in handling any materials that contain chemicals. Refer to product manufacturer's SDS for more information on chemical components and safe handling practices.



- A. If available, follow surface paver Manufacturer instructions for cleaning, sealing, etc. If no information is provided by the Manufacturer, the following can serve as a general guideline.
- B. Cleaning: If desired, Bison 2CM & Paver Tray system may be periodically cleaned. All spills should be cleaned as quickly as possible. Before handling stain removing chemicals remember to use personal protective equipment such as safety glasses, respirators, and gloves as recommended per manufacturer safety data sheet (SDS). Prior to application of any cleaners, sweep thoroughly and mop with a clean damp mop using a PH-balanced mild household detergent such as diluted dish soap to gently remove dirt, debris, or light stains. Always check with the manufacturer of your roof membrane and drainage system to ensure that any cleaning solution or by-product will not compromise or damage the waterproofing or drainage systems including any and all environmental impact. Always refer to product manufacturer's SDS for more information on chemical components and safe handling practices and disposal considerations for local, state, and federal laws. Bison recommends first testing on an inconspicuous area of 2CM paver before applying to the entire deck surface. Bison recommends using ZEP ALL-IN-1 Premium Pressure Wash concentrate (Dilution ratio 1:20 per manufacturer recommendation) for periodic cleaning and maintenance followed by thorough rinsing. You may use a pressure washer on 2CM pavers at a suggested maximum of 1200 PSI. Test an inconspicuous area first and be careful to clean the entire deck to avoid lap marks. Avoid direct pressure stream on bonding adhesive. Rinse thoroughly with clean, clear water to remove any concentrates or solutions. Rinsing is a critical step in the maintenance procedure to prevent chemical deposit buildup. After rinsing, removing any standing water with a squeegee or similar will help prevent difficult to remove dirt or chemical deposits on drying surface.
- C. Deep Cleaning: When necessary, scrub with cotton mop, cloth, sponge, or non-metallic brush. DO NOT use abrasive cleaners, brushes with hard or metal bristles, scouring pads, steel wool, or sandpaper. DO NOT use scouring powders, as these products contain abrasives that may scratch the surface of the paver. DO NOT use vinegar or any cleaners containing acids, alcohols, or strong alkaline agents. Products with high acid or ammonia content are not recommended. Acid washing is not recommended. Acids, like orange extract and vinegar (including any substance with a PH lower than 7) can damage the glazed surface of the tile and alkaline solutions like ammonia or bleach (including any substance with a PH higher than 7) can discolor pavers and degrade adhesive bond. DO NOT use ammonia, alcohols, calcium hypochlorite, methylene chloride, potassium permanganate, liquid chlorine, or any other strong oxidizing agents. Commercial floor scrubbers or floor buffing machines are not recommended due to their potential to damage the deck system. After referencing the roofing and drainage system's safety data sheets assuring chemical and environmental stability of materials, following the steps from the cleaning section above, Bison recommends the following cleaners for specific stain types: 30 Seconds Outdoor Cleaner (1:1), or Simple Green Concrete and Driveway Cleaner (1:20) for dirt, grease, grime, mold, mildew, and algae; FILA CLEANALL (1:30), or FILA PS87 (1:5) for food, drink, dyes, oils, and organic stains; or FILA DETERDEK (1:5), or Simple Green Lime Scale Remover (1:5) for rust or lime scale stains. Be sure to avoid any unnecessary chemical exposure with chemicals mentioned in this section on paver tray adhesive bond or galvanized steel as these materials are more susceptible to harsh cleaners and chemicals.
- D. Sealing: Applying sealer or wax to pavers is not recommended.
- E. Water and Snow Removal: Always rinse pavers thoroughly after any application of ice-melt to avoid the buildup of salt crystals. After rinsing squeegee pavers dry.

F. Visual Observation: Check for rocking pavers and adjust or shim immediately. Failure to do so can cause a tripping hazard. Periodically check spacer tabs and immediately replace broken tabs to limit deck movement. Make sure the edge restraint stays intact and structurally sound.

PROPOSITION 65

⚠WARNING: This product can expose you to chemicals including nickel (metallic), which are known to the State of California to cause cancer, and lead, which is known to the State of California to cause cancer and birth defects or other reproductive harm. For more information go to www.P65Warnings.ca.gov.

END OF SECTION

<p>PT-TRAY-2424-4 PAVER SUPPORT TRAY</p> 	<p>PT-TRAY-2424-4 Dimensions: 23.43"L x 23.43"W x 0.35"H Special Order and Custom Sizes Available Origin: Denver, CO USA</p>	<p>FS-12 12" Fastening Spline</p> 	<p>FS-12 Secures Bison Paver Trays to Bison Pedestals. Long screw for use with Bison Adjustable Pedestals; Short screw for use with Bison HD50 and HD75 Fixed Height Pedestals.</p>
---	---	---	--